Ref. Certif. No.

SG SGS-00437

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC LFP Battery Energy Storage System (PCS integrated)
Name and address of the applicant	RelyEZ Energy Storage Technology Co., Ltd. A3603 Building 11A, Shenzhen Bay Science and Technology Ecological Park, No. 16 Keji South Road, Nanshan District, Shenzhen, Guangdong, China
Name and address of the manufacturer	Jiangsu RelyEZ Energy Storage Technology Co., Ltd. 130 Tonggang Road, New District, Zhenjiang, Jiangsu, China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Jiangsu RelyEZ Energy Storage Technology Co., Ltd. 130 Tonggang Road, New District, Zhenjiang, Jiangsu, China
Ratings and principal characteristics	Input / Output: 230/400 V~, 50 Hz, 3W+N+PE, 210 A max., 133 kW max.; Nominal voltage of battery unit: 832 Vd.c.; Capacity: 314 Ah; Protective Class I; IP54
Trademark / Brand (if any)	RelyEZ
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	YXYK-125K/552314-L
Additional information (if necessary may also be reported on page 2)	- National Differences: EU Group Differences
A sample of the product was tested and found to be in conformity with	IEC 62477-1:2012, IEC 62477-1:2012/AMD1:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	CQES240500038201

This CB Test Certificate is issued by the National Certification Body

SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way
#03-01 Singapore 609957

Date: 26/08/2024

Signature:

Ruby Yan
Certifier